

Energy consumption ON/OFF vs Modulating control

Engineering
GREAT Solutions

2nd International HVAC Conference

Professional Chamber of Mechanical Engineers, Montenegro

22-23 September 2016, Budva

Engineering
GREAT
Solutions

 IMI PNEUMATEX

 IMI TA

 IMI HEIMEIER

Introduction



Ing. Károly Vinkler
Hydronic College Manager
Southern Europe

Kunigunda útja 60.
H-1037 BUDAPEST

mobile +36 30 9772 659
direct +36 1 453 6072

mail: karoly.vinkler@imi-hydronic.com

Comparison of energy consumption ON/OFF vs Modulating control at the fancoil units

Engineering
GREAT
Solutions

IMI PNEUMATEX

IMI TA

IMI HEIMEIER

System

Basic technical data

Engineering
GREAT
Solutions


 **IMI PNEUMATEX**

 **IMI TA**

 **IMI HEIMEIER**

Office building (fictive) – cooling system

- ▶ **System:** air conditioning system (cooling side)
- ▶ **Building:** office building – $\sim 10,000 \text{ m}^2$
- ▶ **Cooling capacity:** 800 kW
- ▶ **Number of chillers:** 2 pcs
- ▶ **Type of chiller:** constant flow through evaporator
- ▶ **Type of the system:** cooling system with pressure break tank
- ▶ **Consumer system:** fan coils and AHU - variable flow system
 - power_{fancoil}: 60%
 - power_{AHU}: 40%
- ▶ **Temperature regime:** 7/12/24 °C; design outdoor temp.: 36 °C
- ▶ **Water flow rates and pump heads:**
 - fan coil: 480 kW; $\Delta t=5\text{K}$ -> 82,500 l/h (H= 12 m)
 - AHU: 320 kW; $\Delta t=5\text{K}$ -> 55,000 l/h (H= 15 m)
 - chillers (2): 400 kW/chiller -> 68,750 l/h (H= 10 m)




Price of electrical energy


- ▶ **Price of the electrical energy:** 0.18 EUR/kWh
- ▶ **Specific CO₂ emission:** 150 g/kWh



Load profiles



- ▶ **Daily load profile** (estimated)
0:00 – 24:00



- ▶ **Monthly load profile** (estimated)
January – December



- ▶ **Number of working days** (estimated)
6 days/week

ON/OFF vs Modulating control

General information

Engineering
GREAT
Solutions

 IMI PNEUMATEX

 IMI TA

 IMI HEIMEIER

Modulating vs ON/OFF control

Imagine, the whole installation with **identical fancoils** actually operates at **50% of output power**.

The total system flow is*:

Modulating control

~20%

All valves delivers
20% of flow

On-off control


~50%

50% valves are fully open
50% valves are closed


*Using PIBCV valve

Room temperature – ON/OFF vs Modulating control

ON/OFF control



Modulating control




Modulating vs ON/OFF control

At 50% of power demand


Modulating control

Desired temperature

Flow



On-off control



Room temperature:	Stable, accurate
Flow rate:	Adequate to power
Pumping costs:	Low
Return temperature:	Ideal
Energy efficiency:	High

Oscillations
High/Zero
Higher
Affected
„Good“

Hydronic system

General information

Engineering
GREAT Solutions

Engineering
GREAT
Solutions


 **IMI PNEUMATEX**

 **IMI TA**

 **IMI HEIMEIER**

Engineering
GREAT Solutions

Solution A




▶ 4-pipe fancoils (ON/OFF control):

- variable flow system
- TA-Compact-P two-way control valve
 - linear valve characteristic
 - linear lift limitation
 - Δp stabilization: PIBCV
 - EMO-T actuator for ON/OFF control


▶ AHU (modulating control 1):

- variable flow system
- CV 216 GG two-way control valve
 - EQM valve characteristic
 - Δp stabilization: *pressure independent modules* (min. authority 0.25)
 - MC 100 actuator for modulating control



Engineering
GREAT Solutions

Solution B



▶ 4-pipe fancoils (modulating control):

- variable flow system
- TA-Modulator two-way control valve
 - EQM valve characteristic
 - exponential lift limitation
 - Δp stabilization: PIBCV
 - TA-Slider 160 actuator for modulating control

▶ AHU (modulating control 2):

- variable flow system
- TA-Fusion-P two-way control valve
 - EQM valve characteristic
 - Δp stabilization: PIBCV
 - TA-Slider 750 actuator for modulating control



Energy Insights Calculator

Basic information

Engineering
GREAT Solutions

Engineering
GREAT
Solutions


 IMI PNEUMATEX

 IMI TA

 IMI HEIMEIER

Energy Insights Calculator

Engineering
GREAT Solutions



The Energy Insights Calculator is a software for comparing the different energy consumptions of the pumps, water chillers, heat pumps and condensing boilers, developed by the Hydronic College.

Summary of costs This worksheet shows the different annual energy costs of the pumps, chillers, heat pumps and condensing boilers, before and after the renovation of the system.

Load profile Here you can identify the daily, weekly and monthly (annual) load profiles of the system.

Pump You can identify the basic technical data on the PUMP worksheet. The P (PUMP) worksheet shows the graph of the results.

Chiller You can identify the basic technical data on the CHILLER and CH EFFICIENCY worksheets. The CH DIAGRAMS worksheet shows the graph of the results.

Heat pump You can identify the basic technical data on the HEAT PUMP and HP EFFICIENCY worksheets. The HP DIAGRAMS worksheet shows the graph of the results.

Condensing boiler You can identify the basic technical data on the CONDENSING BOILER and CB EFFICIENCY worksheets. The CB DIAGRAMS worksheet shows the graph of the results.

Room Temp. You can identify the basic technical data on the ROOM TEMP. worksheet.

The yellow cells are the ones that have to be filled

IMI Hydronic Engineering

New functions

- VSP with remote Δp sensor
- El Calculator takes into consideration for modulating control mode:
 - + Min. authority of CV
 - + Rangeability of CV
 - + Thermal efficiency

COMPARISON OF THE ANNUAL ENERGY COSTS												
NAME	BEFORE THE RENOVATION						AFTER THE RENOVATION					
	Annual energy	Energy charge (€)	Annual CO ₂	Annual energy	Energy charge (€)	Annual CO ₂	Annual energy	Energy charge (€)	Annual CO ₂	Annual energy	Energy charge (€)	Annual CO ₂
CHILLER	10000	10000	10000	10000	10000	10000	10000	10000	10000	10000	10000	10000
HEAT PUMP	20000	20000	20000	20000	20000	20000	20000	20000	20000	20000	20000	20000
CONDENSING BOILER	30000	30000	30000	30000	30000	30000	30000	30000	30000	30000	30000	30000
PUMP	40000	40000	40000	40000	40000	40000	40000	40000	40000	40000	40000	40000
ROOM TEMP.	50000	50000	50000	50000	50000	50000	50000	50000	50000	50000	50000	50000
TOTAL	100000	100000	100000	100000	100000	100000	100000	100000	100000	100000	100000	100000

- ▶ The Energy Insights Calculator is a software for comparing the different energy consumptions of the
 - pumps,
 - water chillers,
 - heat pumps and
 - condensing boilers.
- ▶ This software can be used to present the difference between the energy consumption of the pumps, water chillers, heat pumps and condensing boilers which are installed and operated at different conditions.
- ▶ Developed by the Hydronic College.

Results

Energy Insights Calculator

Engineering
GREAT Solutions


Engineering
GREAT
Solutions

 IMI PNEUMATEX

 IMI TA


 IMI HEIMEIER

Annual load profile



Annual Load profile of the system

- working days: 210 days




Annual Load profile of the chillers

- working days: 107 days/chiller




Pumping curves – fan coil system



Solution A ON/OFF control

- Δp stabilization: PIBCVCV
- VSP: constant Δp control

50% of load → 45,000 l/h





Solution B Modulating control

- Δp stabilization: PIBCVCV
- VSP: constant Δp control



50% of load → 20,000 l/h



Pumping curves – AHU system



50% of load → 12,500 l/h



50% of load → 12,500 l/h

Solution A Modulating control 1

- Δp stabilization: pressure independent modules
- VSP: constant Δp control

Solution B Modulating control 2

- Δp stabilization: PIBCV
- VSP: constant Δp control



Engineering
GREAT Solutions

Pumping energy saving

COMPARISON OF THE ANNUAL ENERGY COSTS							
Hydronic College	Solution A			Solution B			
	Annual energy consumption**	Annual energy cost EUR/year	Annual CO ₂ emission [kg/year]	Annual energy consumption**	Annual energy cost EUR/year	Annual CO ₂ emission [kg/year]	
Pump							
Fan coil	13 878.0	2 498.0	2 081.7	6 998.0	1 259.6	1 049.7	
AHU	5 960.0	1 072.8	894.0	5 831.0	1 049.6	874.7	
Chiller 1	7 401.0	1 332.2	1 110.2	7 401.0	1 332.2	1 110.2	
Chiller 2	7 401.0	1 332.2	1 110.2	7 401.0	1 332.2	1 110.2	
	0.0	0.0	0.0	0.0	0.0	0.0	
	0.0	0.0	0.0	0.0	0.0	0.0	
Chiller	0.0	0.0	0.0	0.0	0.0	0.0	
Heat pump	0.0	0.0	0.0	0.0	0.0	0.0	
Condensing boiler	0.0	0.0	0.0	0.0	0.0	0.0	
TOTAL	El. energy	34 640.0	6 235.2	5 196.0	27 631.0	4 973.6	4 144.7
	Gas	0.0	0.0	0.0	0.0	0.0	0.0
		6 235.2	5 196.0		4 973.6	4 144.7	
				Saving			
				-1 261.6	-1 051.4		
				Annual energy cost saving EUR/year	Annual CO ₂ emission saving [kg/year]		
** [kWh/year] for the pumps, chillers and heat pumps							
** [m ³ /year] for the condensing boilers							
Price of electrical energy	0.18	EUR/kWh					
Price of gas	0.00	EUR/m ³					
Specific CO₂ emission	150.0	g/kWh el. energy					
Specific CO₂ emission	0.0	g/m ³ gas					
Project:	TA-COMPACT-P vs TA-Modulator		IMI Hydronic Engineering				
Date:	13.01.2016						
Made by:	Hydronic College						

Solution A: 34,640 kWh

Solution B: 27,631 kWh

Savings:

- ▶ - 1,261 EUR
- ▶ - 1,051 kg CO₂
- ▶ - 20.2 %




Chiller efficiency – Solution A


Result	
Real Seasonal Energy Efficiency Ratio of the chiller	3.46
Average supply water temperature (T_s) of the chiller [°C]	6.5
Average return water temperature (T_r) of the chiller [°C]	8.6
Minimum controllable flow at the consumers [%]	2.0
Minimum controllable power at the consumers [%]	6.5
Thermal efficiency	0.29

▶ ON/OFF control (FC) & modulating control 1 (AHU)

- due to the **negative incompatibility** of the flows ($V_s > V_p$) the set point of the chiller is lower with 0.5 K (estimated value), see the graph!
- due to the **ON/OFF control** the average **room temperature of the building is lower** than the design value with: 0.5 K (estimated value)
- **ESEER of the chiller: 3.8 (optimum)**



By pass flow




Chiller efficiency – Solution B


Result	
Real Seasonal Energy Efficiency Ratio of the chiller	3.60
Average supply water temperature (T_s) of the chiller [°C]	7.0
Average return water temperature (T_r) of the chiller [°C]	9.9
Minimum controllable flow at the consumers [%]	1.2
Minimum controllable power at the consumers [%]	4.0
Thermal efficiency	0.29

▶ Modulating control (FC) & modulating control 2 (AHU)

- there is **no negative incompatibility** of flow
- **accurate room temperature control**
- **ESEER of the chiller: 3.8 (optimum)**



By pass flow



Engineering
GREAT Solutions

Chiller energy saving

COMPARISON OF THE ANNUAL ENERGY COSTS							
Hydronic College		Solution A			Solution B		
		Annual energy consumption**	Annual energy cost EUR/year	Annual CO ₂ emission [kg/year]	Annual energy consumption**	Annual energy cost EUR/year	Annual CO ₂ emission [kg/year]
Pump							
Fan coil		0.0	0.0	0.0	0.0	0.0	
AHU		0.0	0.0	0.0	0.0	0.0	
Chiller 1		0.0	0.0	0.0	0.0	0.0	
Chiller 2		0.0	0.0	0.0	0.0	0.0	
		0.0	0.0	0.0	0.0	0.0	
		0.0	0.0	0.0	0.0	0.0	
Chiller		529 079.4	95 234.3	79 361.9	475 055.0	85 509.9	
Heat pump		0.0	0.0	0.0	0.0	0.0	
Condensing boiler		0.0	0.0	0.0	0.0	0.0	
TOTAL	El. energy	529 079.4	95 234.3	79 361.9	475 055.0	85 509.9	
	Gas	0.0	0.0	0.0	0.0	0.0	
			95 234.3	79 361.9		85 509.9	
						71 258.3	
						Saving	
					-9 724.4	-8 103.7	
					Annual energy cost saving EUR/year	Annual CO ₂ emission saving [kg/year]	
** [kWh/year] for the pumps, chillers and heat pumps							
** [m ³ /year] for the condensing boilers							
Price of electrical energy		0.18	EUR/kWh				
Price of gas		0.00	EUR/m ³				
Specific CO ₂ emission		150.0	g/kWh el. energy				
Specific CO ₂ emission		0.0	g/m ³ gas				
Project:		TA-COMPACT-P vs TA-Modulator			IMI Hydronic Engineering		
Date:		13.01.2016					
Made by:		Hydronic College					

Solution A: 95,234 kWh

Solution B: 85,509 kWh


Savings:

- ▶ - 9,724 EUR
- ▶ - 8,103 kg CO₂
- ▶ - 10.2 %



Engineering
GREAT Solutions

Total energy saving

COMPARISON OF THE ANNUAL ENERGY COSTS							
Hydronic College		Solution A			Solution B		
		Annual energy consumption**	Annual energy cost EUR/year	Annual CO ₂ emission [kg/year]	Annual energy consumption**	Annual energy cost EUR/year	Annual CO ₂ emission [kg/year]
Pump							
Fan coil		13 878.0	2 498.0	2 081.7	6 998.0	1 259.6	1 049.7
AHU		5 960.0	1 072.8	894.0	5 831.0	1 049.6	874.7
Chiller 1		7 401.0	1 332.2	1 110.2	7 401.0	1 332.2	1 110.2
Chiller 2		7 401.0	1 332.2	1 110.2	7 401.0	1 332.2	1 110.2
		0.0	0.0	0.0	0.0	0.0	0.0
		0.0	0.0	0.0	0.0	0.0	0.0
Chiller		529 079.4	95 234.3	79 361.9	475 055.0	85 509.9	71 258.3
Heat pump		0.0	0.0	0.0	0.0	0.0	0.0
Condensing boiler		0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	El. energy	563 719.4	101 469.5	84 557.9	502 686.0	90 483.5	75 402.9
	Gas	0.0	0.0	0.0	0.0	0.0	0.0
			101 469.5	84 557.9		90 483.5	75 402.9
				Saving			
				-10 986.0	-9 155.0		
				Annual energy cost saving EUR/year	Annual CO ₂ emission saving [kg/year]		
Price of electrical energy		0.18	EUR/kWh				
Price of gas		0.00	EUR/m ³				
Specific CO₂ emission		150.0	g/kWh el. energy				
Specific CO₂ emission		0.0	g/m ³ gas				
Project:		TA-COMPACT-P vs TA-Modulator					
Date:		13.01.2016					
Made by:		Hydronic college					

Solution A: 101,469 kWh

Solution B: 90,483 kWh

Savings:

- ▶ - 10,986 EUR
- ▶ - 9,155 kg CO₂
- ▶ - 10.8 %



Thank you for your attention!

*Engineering
GREAT
Solutions*

 IMI PNEUMATEX

 IMI TA

 IMI HEIMEIER